

Full Cutoff Lighting Demonstration Project

David S. Liebl*, Donald P. Sanford - University of Wisconsin Madison

Summary

The UW-Madison-Arboretum, McKay Visitor Center outdoor lighting demonstration project, sponsored by the University of Wisconsin and Madison Gas and Electric (MG&E), showed the advantages of using full-cutoff light fixtures. Five of the McKay Center's six parking and security lights were retrofitted by MG&E with Hubbell Skycap full cutoff shields. Measurements taken before and after the retrofit showed a doubling of illumination under the Skycaps, with no increase in power consumption. In addition, one unshielded 150w high pressure sodium fixture was replaced with a shielded 100w fixture, resulting in a 30% reduction in electric power use, with no reduction in illumination. In all cases, the Skycaps eliminated upward and outward glare.

Demonstration Site

The University of Wisconsin-Arboretum is an ecological research and teaching facility located on 1200 acres adjacent to Lake Wingra, in Madison, WI. The McKay Visitor Center parking lot accommodates approximately 50 cars in two parking aisles separated by a large median. Security lighting for the parking lot and visitor center entrance is provided by six 150w NEMA style lights on five 30 foot poles (one pole holds two fixtures).

Measurements

Illumination measurements were taken before and after the installation of Hubbell Skycaps, using a Gossen-Panlux Electronic light meter held six feet above ground level and perpendicular to the incident ray from each fixture.

Before Skycaps

Pole A) Two 150w NEMA style fixtures - unshielded

- 0' = 1.9 footcandle (fc)
- 20' = 1.25fc
- 60' = 0.5fc
- 100' = 0.1fc

Pole B) One 150w NEMA style fixture - unshielded

- 0' = 1.2fc
- 20' = 1.7fc
- 60' = 0.5fc

Locations equidistant between poles A & B

- 100' = 1.5fc
- 128' = 0.1fc

After Skycaps

Pole A) Two 150w NEMA style fixtures - retrofitted with Hubbell Skycaps

- 0' = 3.7fc
- 20' = 2.5fc
- 60' = 0.3fc
- 100' = 0.05fc

Pole B) One 100w NEMA style fixture - retrofitted with Hubbell Skycap

- 0' = 0.7fc
- 20' = 1.1fc
- 60' = 0.2fc

Locations equidistant between poles A & B

- 100' = 0.05fc
- 128' = less than 0.05fc

* For More Information

David S. Liebl
UW-College of Engineering
432 N. Lake Street, Room 311
Madison, WI 53706
608/265-2360
liebl@epd.engr.wisc.edu



Parking Lot
Before Skycaps



Parking Lot
After Skycaps

Results

Illumination Engineering Society (IES) recommendations for low usage parking lots are an average illumination of 0.8fc, with a minimum illumination of 0.2fc. Initially, the 150w unshielded lights (Pole A) provided illumination levels of 1.9fc - .5fc, or about two times the recommended values. Retrofitted 150w lights (Pole A) now give illumination levels of about 3.7fc - 0.3fc, or about four times the recommended values. Lowering the shielded fixture wattage to 100w (Pole B) resulted in illumination levels approximately 25% above recommended levels, with a 30% savings in energy usage. Cutoff of stray light is excellent with the Hubbell Skycaps, which give an effective illumination radius of about 50 - 60'.

Prior to the retrofit, glare from the Arboretum parking lot lights could be easily seen from 1.2 miles across Lake Wingra. After the retrofit, only glare from the remaining unshielded fixture is visible.

Acknowledgments

We wish to thank Ruth Miller of Madison Gas and Electric for her enthusiastic support of this project.